

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0075:158 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653
Contact: *Brian Reynolds (203) 484-1200 FAX (203) 484-7309

DESIGN: Models MS-9200, MS-9200E and AMS-9200 fire alarm control units. Local, *central station, auxiliary, remote station, proprietary service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

MS-9200	Control Unit
RTM-8F	Relay Module
ZDM-16F	Annunciator Driver
PIM-24	Printer/PC Interface Module
LCD-40, LCD-40L	Remote LCD Annunciator
DIM-485	Display Interface module
XRM-24	Transformer
*UDACTF	Digital Alarm Communicator Transmitter

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. These control units can generate a distinctive three-pulse Temporal Pattern Fire alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to listee's Installation Instructions Manual for details.

NOTE: For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

*Rev. 2-14-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 14, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager